

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Aneta Fabianova
"the Owner"

RE: The housing premises located in Mountain View County, Alberta and municipally described as:
29274 Range Road 52
NE-15-29-05-W5M

WHEREAS I, an **Executive Officer of Alberta Health Services**, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on September 13, 2022 which showed the presence of Total Coliform bacteria.
- b. The ground water is subject to contamination as the well is located in a pit and the bottom of the pit is submerged in stagnant water.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and Housing Regulation, Alberta Regulation 173/1999, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

- a. Water supplying the premises may be unsafe for human consumption as indicated by a water sample collected on September 13, 2022 showed the presence of Total Coliform bacteria, which is in contravention of the Housing Regulation Section 3(1)(b)(iii) which states "Subject to subsection (3) and section 4, an owner shall ensure that the occupants of the housing premises are supplied with adequate running hot and cold water that is safe for human consumption".
- b. The well is located in a pit and the well pit is submerged in stagnant water, which is in contravention of the Housing Regulation Section 3(1)(b)(iii) which states "Subject to subsection (3) and section 4, an owner shall ensure that the occupants of the housing premises are supplied with adequate running hot and cold water that is safe for human consumption".

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

1. That the owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. That the Owner immediately issues a Boil Water Advisory to all occupants of the above noted premises, instructing them to boil the water for a minimum of one minute prior to ingesting.
 - b. Provide bottled water or water from another source that is approved by Alberta Health Services for all users to drink and cook with.
 - c. Eliminate the well pit, evaluate the groundwater supply, and conduct any necessary maintenance work on the drinking water system to render the water potable and protected from contamination. Then monitor the bacteriological quality of the well on a weekly basis for up to a year as per direction of an Executive Officer of Alberta Health Services.
 - or
Install water treatment capable of treating groundwater under the direct influence of surface water. Any water treatment plans must be approved by an Executive Officer of Alberta Health Services prior to being installed.
 - or
Install a CSA approved cistern of adequate size and haul potable water.
 - or
Connect to another potable water supply.
2. The work referred to in **paragraph 1(a) – 1(b)** must be completed immediately and continue until rescinded by an Executive Officer.
3. A plan outlining the intended work to be done to comply with **paragraph 1(c)**, complete with acceptable timelines, must be provided to the undersigned or another Executive Officer of Alberta Health Services by December 15, 2022.
4. The work referred to in paragraph 1(c) must be completed to the satisfaction of the undersigned or an executive officer of Alberta Health Services by March 1, 2023.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Airdrie, Alberta, November 21, 2022

Confirmation of a verbal order issued to Aneta Fabianova on November 17, 2022.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

Order of An Executive Officer – Boil Water Order

RE: Those premises located in Mountain View County, Alberta and municipally described as: 29274 Range Road 52, NE-15-29-05-W5M, Mountain View County, Alberta

Page 4 of 4

Airdrie • Airdrie Health Annex • Environmental Public Health

217 Centre Avenue SW Airdrie, Alberta, Canada T4B 0R3

www.ahs.ca/eph