

ORDER OF AN EXECUTIVE OFFICER CLOSED FOR TENANT ACCOMMODATION PURPOSES ORDER TO VACATE

To: Karen Turner

"the Owner"

And To: All Occupant(s) of the following Housing premises:

RE: Those housing premises located in Camrose, Alberta and municipally described as:

7007 - 49A Avenue – Basement Suite.

WHEREAS I, an Executive Officer of Alberta Health Services, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

a. The horizontal slider window in the bedroom has an openable space of approximately 18 inches by 26 inches.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

a. The horizontal slider window in the bedroom has an openable space of approximately 18 inches by 26 inches. This is in contravention of Section 3(b)(ii) of the Minimum Housing and Health Standards which states: "Windows referred to in section 3(b)(i) shall provide unobstructed openings with areas not less than 0.35 m² (3.8ft²), with no dimension less than 380 mm (15")."

AND WHEREAS, by virtue of the foregoing, the above noted premises are hereby declared to be **Closed for Tenant Accommodation Purposes**.

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

- 1. That the occupants vacate the above noted premises on or before August 29, 2024.
- 2. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
 - a. Ensure that windows in rooms used for sleeping provide an unobstructed opening with areas not less than 3.8 square feet (0.35 square metres) with no dimension less than 15 inches.

3. That until such time as the work referred to above is completed to the satisfaction of an Executive Officer of Alberta Health Services; the above noted premises shall remain closed for tenant accommodation purposes.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Camrose, Alberta, July 11, 2024. Confirmation of a verbal order issued to Karen Turner and Syd Francis on July 11, 2024.

Executive Officer
Environmental Health Officer

You have the right to appeal

A person who

- a) is directly affected by a decision of a Regional Health Authority, and
- b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board c/o Central Reception Main Floor, ATB Place North Tower 10025 Jasper Avenue NW Edmonton, Alberta, T5J 1S6 Phone: 780-222-5186

Fax: 780-422-0914

Email: HealthAppealBoard@gov.ab.ca

Website: https://www.alberta.ca/public-health-appeal-board.aspx

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or https://www.alberta.ca/alberta-kings-printer.aspx.

Order o	of an Executive C	Officer - Closed fo	or Tenant Accommo	dation - Order to \	√acate	
RE:	The premises loc	cated in Camrose,	Alberta and municip	ally described as: 7	7007 - 49A Avenu	e - Basement Suite
Page 3	of 3		•	-		

Copies of standards are available by visiting: https://www.alberta.ca/health-standards-and-guidelines.aspx

Template revised October 13, 2022

Camrose • Camrose Community Health Centre Briarcrest • Environmental Public Health
5510 46 Avenue, Camrose, Alberta, Canada T4V 4P8