

## ORDER OF AN EXECUTIVE OFFICER

**To:** Terry Paranych Group Ltd. Heidi Paranych "Property Manager"

**RE:** Those housing premises located in Edmonton, Alberta and municipally described as:

3615 119 Avenue NW Common Area

WHEREAS I, an Executive Officer of Alberta Health Services, have inspected the above noted premises pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

**AND WHEREAS** such inspection disclosed that the following conditions exist in and about the above noted premises which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. The height of the guard on the third floor was measured and found to be 32 inches high with an elevation difference of greater than six feet. This effects the North and South guards.
- b. The width of the spindles was taken and found to be  $5 \frac{1}{2}$  inches wide. This effects the North and South railings.
- c. The width of the spindles where the railing turns was measured and found to be 6 inches wide. This effects the North and South and railings.

**AND WHEREAS** such inspection disclosed that the following breaches of the Public Health Act and the Housing Regulation, Alberta Regulation 173/99, and the Minimum Housing and Health Standards exist in and about the above noted premises, namely:

a. Items (a, b, and c) was in contravention of section III(3)(c) of the Minimum Housing and Health Standards which states that: Inside or outside stairs or porches including all treads, risers, supporting structural members, handrails, guards and balconies, shall be maintained in good repair and shall comply with the requirements of the Alberta Building Code or a Professional Engineer design.

## NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

- 1. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted premises, namely:
  - a. Modifying or replace the guards and railings to ensure that it complies with the minimum housing and health standard and the requirement of the Alberta Building Code.
- 2. The work referred to in paragraph 1 shall be completed by 15 February 2024

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at Edmonton, Alberta, 14 August 2023 Confirmation of a verbal order issued to Sonam Bhutia Senior Property Manager 08 August 2023

Executive Officer
Alberta Health Services

## You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and

b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board c/o Central Reception Main Floor, ATB Place North Tower 10025 Jasper Avenue NW Edmonton, Alberta, T5J 1S6 Phone: 780-222-5186

Fax: 780-422-0914

Email: HealthAppealBoard@gov.ab.ca

Website: https://www.alberta.ca/public-health-appeal-board.aspx

A Notice of Appeal form may be obtained by contacting Alberta Health Services at 780-342-0122 or by contacting the Public Health Appeal Board.

## Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Health Legislation and regulations are available for purchase. Please contact Alberta Queen's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or www.qp.gov.ab.ca.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: https://www.alberta.ca/health-standards-and-guidelines.aspx