

ORDER OF AN EXECUTIVE OFFICER Boil Water Order

To: Lionsheart Wholeness Centre Inc.
Wanda Rowe
Barbara Joyce Rowe
2196567 Alberta Ltd.
Ivan Harper
Laurie Ann Jimmy
Richard Stanley
Joseph Waskewitch Jr.
“the Owner”

RE: The Drinking Water Supply located in Legal, Alberta and municipally described as:
Lionsheart Wholeness Centre, 57413 Lily Lake Road, Legal, Alberta, T0G 1L0

WHEREAS I, an **Executive Officer** of **Alberta Health Services**, have inspected the above noted drinking water supply pursuant to the provisions of the Public Health Act, RSA 2000, c. P-37, as amended;

AND WHEREAS such inspection disclosed that the following conditions exist in and about the above noted Drinking Water Supply which are or may become injurious or dangerous to the public health or which might hinder in any manner the prevention or suppression of disease, namely:

- a. Water line pressure was observed to have been reduced and/or lost, possibly due to loss of power to the facility. This may lead to back pressure or siphonage in the water distribution system, thereby contaminating the drinking water.

AND WHEREAS such inspection disclosed that the following breaches of the Public Health Act and the Nuisance and General Sanitation Regulation, Alberta Regulation 243/2003 exist in and about the above noted Drinking Water Supply, namely:

- a. Water line pressure was observed to have been reduced and/or lost, possibly due to loss of power to the facility. This may lead to back pressure or siphonage in the water distribution system, thereby contaminating the drinking water. This is in contravention of the **Nuisance and General Sanitation Regulation Section 11**, which states that, “*Where a person provides a source of water that the person intends to be used or realizes or ought to realize will be used by the public for human consumption, the person shall ensure that the water is potable.*”

AND WHEREAS by virtue of the foregoing, the above noted Drinking Water Supply is hereby declared **unfit for human consumption**;

NOW THEREFORE, I hereby **ORDER** and **DIRECT**:

Order of An Executive Officer – Boil Water Order

RE: The Drinking Water Supply located in Legal, Alberta and municipally described as: Lot 6 Block 1 Plan 8521373

1. That the Owner immediately issue a Boil Water Advisory to all users of the above noted Drinking Water Supply.
2. If water cannot be boiled, the Owner shall provide an alternate source of potable water to occupants of the premises deemed suitable by the Executive Officer.
3. That the Owner immediately undertake and diligently pursue the completion of the following work in and about the above noted drinking water supply, namely:
 - a. Address deficiencies identified with the water supply to the satisfaction of Executive Officer.
 - b. Once the deficiencies are addressed and supply pressure is restored, flush the affected distribution system to remove any potentially contaminated water.
 - c. After confirming that the distribution system water has been flushed, submit two sets of representative bacteriological samples collected at least 24 hours apart from representative locations from the affected distributions system.
4. That, until such time as the work referred to in paragraph 3 is completed to the satisfaction of the undersigned, or an Executive Officer of Alberta Health Services, and the samples submitted in paragraph 3B. have been confirmed satisfactory, that this order shall remain in effect.

The above conditions were noted at the time of inspection and may not necessarily reflect all deficiencies. You are advised that further work may be required to ensure full compliance with the Public Health Act and regulations, or to prevent a public health nuisance.

DATED at St. Albert, Alberta, December 7, 2023.

Confirmation of a verbal order issued to Wanda Rowe and Laurie Ann Jimmy on December 5, 2023.

Executive Officer
Alberta Health Services

You have the right to appeal

A person who a) is directly affected by a decision of a Regional Health Authority, and
 b) feels himself aggrieved by the decision

may appeal the decision by submitting a Notice of Appeal form within ten (10) days after receiving the order to:

Public Health Appeal Board
c/o Central Reception
Main Floor, ATB Place North Tower
10025 Jasper Avenue NW
Edmonton, Alberta, T5J 1S6
Phone: 780-222-5186
Fax: 780-422-0914
Email: HealthAppealBoard@gov.ab.ca
Website: <https://www.alberta.ca/public-health-appeal-board.aspx>

Order of An Executive Officer – Boil Water Order

RE: The Drinking Water Supply located in Legal, Alberta and municipally described as: Lot 6 Block 1 Plan 8521373

A Notice of Appeal form may be obtained by contacting the Public Health Appeal Board or visiting their website.

Health Legislation, Regulations and Standards

Electronic versions of the Public Health Act and Regulations are available at the Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Health Legislation and regulations are available for purchase. Please contact Alberta King's Printer Bookstore 10611 - 98 Avenue, Main Floor, Park Plaza, Edmonton, Alberta, T5K 2P7 or <https://www.alberta.ca/alberta-kings-printer.aspx>.

Copies of standards are available by contacting the Health Protection Branch of Alberta Health at 780-427-4518 or by visiting: <https://www.alberta.ca/health-standards-and-guidelines.aspx>

St. Albert • St. Albert Community Health Centre • Environmental Public Health

23 Sir Winston Churchill Avenue, St. Albert, Alberta, Canada T8N 2S7

www.ahs.ca/eph